



NOTE:

1. DRAIN ALL LOW POINTS OF SYSTEMS TO NEAREST FLOOR DRAIN.
2. PROVIDE MARINE WATER BOXES FOR BOTH CONDENSER AND EVAPORATOR.
3. COLLECT VENT PIPES FROM ALL REFRIGERANT PRESSURE RELIEF DEVICES AND EXTEND TO EXTERIOR OF BUILDING IN ACCORDANCE WITH ASHRAE STANDARD 15. HEADER SIZE TO EQUAL OR EXCEED TOTAL AREA OF DEVICES CONNECTED TO THE HEADER.
4. PROVIDE MODULATING BUTTERFLY VALVES ON BOTH CHWR & CWR. VALVES CONTROLLED BY ECC.
5. FOR PIPING 6" AND BELOW, MECHANICAL COUPLINGS ARE OPTIONAL. ABOVE 6", WELDED PIPE WITH FLANGES IS THE ONLY APPROVED JOINING METHOD.

Scale: AS SHOWN

ARCHITECT/ENGINEERS:

Drawing Title
AMENDMENT #4
MH005-1

Approved: Project Director

Project Title
PANAMA CITY
JOINT OUTPATIENT CLINIC
VA GULF COAST HEALTH CARE

Location
PANAMA CITY, FLORIDA

Date
09-14-12

Checked

Drawn

Project Number

Building Number

Drawing Number

MH005-1

Dwg. of

Office of
Construction
and Facilities
Management



Department of
Veterans Affairs